



HUBBELL, ROTH & CLARK, INC
Consulting Engineers

Principals	Senior Associates
George E. Hubbell	Gary J. Tressel
Thomas E. Blehl	Lawrence R. Ancypa
Walter H. Alix	Kenneth A. Melchior
Peter T. Roth	Dennis M. Monsere
Michael D. Waring	Randal L. Ford
Keith D. McCormack	David P. Wilcox
Curt A. Christeson	Timothy H. Sullivan
Thomas M. Doran	
Chief Financial Officer	Associates
J. Bruce McFarland	Thomas G. Maxwell
	Nancy M.D. Faught
	Jonathan E. Booth
	Michael C. MacDonald
	Marvin A. Olane
	Richard F. Beaubien
	William R. Davis
	Daniel W. Mitchell
	Jesse B. VanDeCreek
	Robert F. DeFraim
	Marshall J. Grazzoli
	Thomas D. LaCross
	Dennis J. Bencit

**ADDENDUM NO. 2
TO
SPECIFICATIONS AND PLANS
FOR THE
CITY OF HOWELL
BROWNING DRIVE PUMP STATION**

ISSUED: April 6, 2009 (Faxed)

HRC Job No. 20080577

This Addendum is issued prior to receipt of bids to provide for certain changes and clarifications to the specifications and/or the plans, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. All other conditions remain the same.

DRAWING CHANGES

1. Drawing S-1 (Revised and Not Reissued)

1. Under Reinforced Concrete Notes, add the following to the end of Note No. 2: "Epoxy coat all steel reinforcement to comply with 2003 MDOT Standard Specifications for Construction Section 905.03c."
2. In Section No. 1 delete the Note "Temporary Sheet piling to Remain in Place" and substitute with the following: "Temporary Earth Supporting System – Refer to Excavation and Backfill Note No. 9."
3. Under Excavation and Backfill Notes, add the following to the end of Note No. 9: "Refer to Sections 01900, 02140 and 02200 of the Specifications for additional information. See Braced Excavation Notes on this Drawing."
4. Under Brace Excavation Notes, revise Note No. G to: "If steel sheet piling is used for Temporary Earth Supporting System it shall remain in place."

\\nt12\projdocs\200805\20080577\Design\Bid\Specs\Add02\Add02.doc

555 Hulet Drive, PO Box 824
Bloomfield Hills, Michigan 48303-0824
Telephone 248 454 6300 Fax 248 454 6312
www.hrc-engr.com

Engineering. Environment. Excellence.



The Bidder shall acknowledge receipt of this Addendum No. 2 by signing this Addendum No. 2 and including it with the Bid Documents. Bids shall be submitted on the original Specification Section 00300 – Proposal Form. Failure to acknowledge Addendum No. 2 will result in the rejection of the bid.

Prepared by:

HUBBELL, ROTH & CLARK, INC.

A handwritten signature in blue ink, appearing to read "Jonathan Booth", is written over the company name.

Jonathan Booth, P.E.

DMM/cc

pc: All Bidders

City of Howell; T. Wilson, J. Prince, E. Suida
HRC; G. Hubbell, D. Monsere, File

Accepted by:

Company Name: _____

Signature: _____

Written Name & Title: _____

Address: _____

Telephone: _____ Fax: _____