



HUBBELL, ROTH & CLARK, INC
Consulting Engineers

Principals
George E. Hubbell
Thomas E. Biehl
Walter H. Alix
Peter T. Roth
Michael D. Waring
Keith D. McCormack
Curt A. Christeson
Thomas M. Doran

Chief Financial Officer
J. Bruce McFarland

Senior Associates
Gary J. Tressel
Lawrence R. Ancypa
Kenneth A. Melchior
Dennis M. Monsere
Randal L. Ford
David P. Wilcox
Timothy H. Sullivan

Associates
Thomas G. Maxwell
Nancy M.D. Faught
Jonathan E. Booth
Michael C. MacDonald
Marvin A. Olane
Richard F. Beaubien
William R. Davis
Daniel W. Mitchell
Jesse B. VanDeCreek
Robert F. DeFrain
Marshall J. Grazioli
Thomas D. LaCross
Dennis J. Benoit
James F. Burton

FAX ONLY

ADDENDUM NO. 2

2010 ROAD MAINTENANCE PROGRAM CITY OF WIXOM OAKLAND COUNTY, MICHIGAN

April 9, 2010

HRC Job No. 20090524.07

INTENT

This Addendum No. 2 is issued to provide changes to the Contract Documents. The General Conditions and Specifications for the original work and the Contract Drawings are to govern this work unless otherwise revised herein.

CONTRACT DOCUMENTS

1. SPECIFICATION SECTION 00010 – TABLE OF CONTENTS (Specification Section Revised and Not Reissued). This section has been revised to reflect the changes made in this Addendum.
2. SPECIFICATION SECTION 01020 – SUPPLEMENTAL PROJECT NOTES (Specification Section Revised and Not Reissued). The following revisions have been made:

- a. Item 41. STREET SIGN REPLACEMENT (DIVISION A ONLY) - The entire section has been revised to read:

Street signs in Division A must be removed and replaced to meet DG (Diamond-Grade) standards. The Engineer will identify which signs need to be replaced during construction, but this may include road name signs, speed limit signs, stop signs, other cautionary signs, etc. The bid item for REMOVE & REPLACE STREET SIGN (ea) will be paid for each sign installed. For example, a stop sign and two road name signs on the same post will be paid for as 3 ea. The bid item will include all work necessary to remove the existing sign and post, furnishing a new three pound post and sign, and installing the post and signs in the same location as the original sign. All sign text, color, size, location, post length, and number of signs per post must match existing.

- b. Item 42. HMA BASE REPAIRS AND HAND PATCHING (DIVISION A ONLY) – A new section has been added which reads:

Y:\200905\20090524\Design\Bid\Specs\Addendum_2\02Addendum.docx

105 W. Grand River
Howell, Michigan 48843
Telephone 517 552 9199 Fax 517 552 6099
www.hrc-engr.com

Engineering. Environment. Excellence.



After the pavement has been milled in the mill and overlay area in Division A, the Engineer will identify areas where the remainder of the pavement needs to be removed, area excavated and replaced with 12 inches of 21AA limestone, and HMA pavement replaced. The bid item for HMA BASE REPAIRS (syd) will include saw cutting, removing, and properly disposing of the pavement in the areas identified by the Engineer, and placing and compacting new HMA, at a thickness which will bring the HMA to the elevation of the previously milled pavement. The HMA mix placed will be that which is specified on the Construction Drawings. The excavation of existing base and placement and compaction of new 21AA aggregate will be paid using the related items in the proposal.

The bid item for HMA HAND PATCHING (ton) will be used to install new HMA anywhere the existing pavement has to be removed for the purposes of installing new curb, replacing a structure casting, or similar operations. This item of work is separate from HMA BASE REPAIRS, and will not be paid for twice. The bid item HMA HAND PATCHING will include placing and compacting new HMA, at a thickness which will bring the HMA to the elevation of the existing pavement. The HMA mix placed will be that which is specified on the Construction Drawings. Any pavement removal, excavation, or aggregate will be paid for using the related items in the proposal.

A copy of all the amended pages of the Contract Documents have been attached to this Addendum No. 2 and should be utilized during the preparation of the bids and incorporated into the Bid Documents.

The Bidder shall acknowledge receipt of this Addendum No. 2 by signing this Addendum No. 2 and including it with the Bid Documents. Failure to submit Addendum No. 2 will result in the rejection of the bid.

Prepared by:

HUBBELL, ROTH & CLARK, INC.

Joseph A. Heintz

JAH/cc

pc: All Bidders
Wixom; City Manager's Office, M. Howell
HRC; J. Booth, M. Darga, File

Accepted by:

Company Name: _____

Printed Name & Title: _____

Signature: _____

Address: _____

City: _____ State: _____ Zip: _____

Telephone: _____ Fax: _____